

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Flexco Floors

1401 E. 6th Street, Tuscumbia, AL, United States

For the following product(s):

Wall Base:

Base Sculpture® Wall Base, Vinyl Base, Vinyl Accessories, Base 2000® Wall Base, Welding Bead, Subleveler, Health Design™ Wall Base, Wallflower® Wall Base, Wood Elements Wall Base, Rubber Corner Blocks, Mini Corners

This product meets all of the necessary qualifications to be certified for the following claim:

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014

Conforms to California Specification 01350 (Standard Method v1.1, January 1, 2012) for the school classroom¹ and private office² parameters.

¹ Modelded Product Type: 10 in Wall Base

² Modelded Product Type: 4 in Wall Base

Measured Concentration of Total Volatile Organic Compounds (TVOC): Between 0.5 – 5.0 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.1-2010)

Registration # SCS-FS-02239

Valid from: July 1, 2015 to August 31, 2016

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI ACCREDITED PROGRAM
PRODUCT CERTIFICATION
#0821



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA