

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

# Flexco Floors

1401 E. 6th Street, Tuscumbia, AL, United States

For the following product(s):

## Wall Base:

Base 2000® Wall Base, Base Sculptures® Wall Base, Health Design™ Wall Base, Mini Corners, Rubber Corner Blocks, Subleveler, Vinyl Accessories, Vinyl Base, Wallflowers® Wall Base, Welding Bead, Wood Elements Wall Base

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom<sup>1</sup> and private office<sup>2</sup> parameters.

<sup>1</sup> Modeled Product Type: 10 in Wall Base

<sup>2</sup> Modeled Product Type: 4 in Wall Base

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-02239

Valid from: July 1, 2022 to June 30, 2023

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI National Accreditation Board  
ACCREDITED

ISO/IEC 17065  
PRODUCT CERTIFICATION  
BODY



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Executive Vice President  
SCS Global Services  
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA